



Government Of West Bengal
Office Of The Divisional Fire Officer, Jalpaiguri
West Bengal Fire & Emergency Services
Jalpaiguri Fire Station, Race Course Para,
P.O. & P.S. :- Jalpaiguri, Pin:- 735101

Memo no.: WBFES/NZ/FP/476/14

Date: 12-07-2023

From:
Divisional Fire Officer, Jalpaiguri
West Bengal Fire & Emergency Services

To: DARJEELING PUBLIC SCHOOL
DABGRAM, FULBARI, P.O.- SATELLITE TOWNSHIP, DIST- JALPAIGURI

Sub: Renewal of Fire Safety Certificate for the Occupancy G+3 Storied Educational Building, Mouza-Binnaguri, J.L.- No-03, Polt No- 165(RS) Khatian No 1032/1, Street No.-18, , P.S. -N.J.P. DIST:Jalpaiguri,

This is in reference to your application no. 0125191237900108 dated 17-06-2023 regarding the Renewal of Fire Safety Certificate for the Occupancy G+3 Storied Educational Building, Mouza-Binnaguri, J.L.- No-03, Polt No- 165(RS) Khatian No 1032/1, Street No.-18, , P.S. -N.J.P. DIST:Jalpaiguri,

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Renewal of Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

Recommendation:

Note - RFSC has been issued on condition that one stand by pump should be installed within six months.

- 1) Good housekeeping to be maintained both inside as well as outside the building
- 2) Floor Numbers as well as directional signs of escape routes to be prominently displayed
- 3) Fire Notice for evacuation and firefighting to be prepared to display at all vulnerable places in the building
- 4) The occupants, employees and security staff to be made well-conversant about the installed fire safety and protection measures for their use in exigencies
- 5) Mock practice and fire evacuation drills to be organized for the regular periodical performance in accordance to the National Building Code - Part IV.
- 6) Electrical wiring of the afore said building should be checked and maintenance to be done by an licensed electrician.

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the 'Verification of Digitally Signed Document' link and keying in the Unique Number : 0125191237900108.

Page : 1

Vijay Kumar Ghosh
Manager
Darjeeling Public School

Hitog Biswas
Principal
DARJEELING PUBLIC SCHOOL
Dabgram, Fulbari
SILIGURI-734015



- 7) Trained Firemen and Fire Officers in the form of prescribed crew to be maintained for round the clock safety of the establishment.
- 8) Fire License shall have to be obtained for proposed storing and processing L.P.G. and other highly combustible articles.
- 9) First-Aid Fire Fighting system shall be provided as per I.S. Specification.
- 10) All Exit & Entrance should be free from obstruction.

This certificate is valid for three year of WBFS (Fire Prevention and Safety) Rules, 2003 and to be renewed every three year from the date of issue, failing which this shall be revoked automatically.

Vijay Kumar Seth
Manager
Darjeeling Public School

Nitoy Biswas
Principal
DARJEELING PUBLIC SCHOOL
Dabgram, Fulbari
SILIGURI-734015

Signature valid

Digitally Signed
Name: SHUBRA KISHOR AZUMDER
Date: 12-Jul-2023 09:55:43
Reason: Approved
Location: West Bengal

Divisional Fire Officer, Jalpaiguri
West Bengal Fire & Emergency Services



Memo No.: WBFE/DP/1476/14